

# Project Summary

## Stanford Stauffer Hall - Retrofit

October 23, 2010

### General Information

**Project Name** Stanford Stauffer Hall  
**Project Description** Retrofit  
**Company Name**  
**Contact**  
**Address 1**  
**Address 2**  
**City/State**  
**Zip Code**  
**Telephone Number**

### System Summary

**Number of Rooms** 38  
**Number of Exhaust Fans** 1  
**Number of Supply AHU's** 1  
**Number of Central Plants** 1  
**Number of Corridors** 3  
**Number of Fume Hoods** 42  
  
**Total Volume** 186,212 *Cubic Feet*

### System Flows

**Fume Hood demand (with all sashes open)** 29,960 *CFM*  
**Fume Hood demand (with all sashes closed)** 16,755 *CFM*  
**Thermal Demand (maximum cooling)** 26,055 *CFM*  
**Ventilation Demand (occupied)** 17,542 *CFM*  
**Ventilation Demand (unoccupied)** 17,541 *CFM*

### LabPro Diversity Comparison

*Flow Unit: CFM*

	Exhaust System <i>99.00% Design</i>			Supply System <i>99.00% Design</i>			Central Plant <i>99.00% Design</i>		
	Diversity	Design Flow	Average Flow	Diversity	Design Flow	Average Flow	Diversity	Design Flow	Average Flow
<b>CV</b>	100%	42,435	42,435	100%	41,345	41,345	100%	41,345	41,345
<b>CV-UBC</b>	85%	36,010	32,028	84%	34,920	30,938	84%	34,920	30,938
<b>VAV</b>	95%	40,200	37,286	95%	39,110	36,196	95%	39,110	36,196
<b>VAV-UBC</b>	83%	35,323	30,994	83%	34,233	29,904	83%	34,233	29,904

Diversity Calculation: Control Type Design Flow / Constant Volume Design Flow

## Project Cost Comparison

### Stanford Stauffer Hall - Retrofit

October 23, 2010

LabPro Flow Summary	Unit	CV	CV-PHX	VAV	VAV-PHX	CV-UBC	VAV-UBC
Design Exhaust System Flow	CFM	42,435	42,435	40,200	40,200	36,010	35,323
Average Exhaust System Flow	CFM	42,435	42,435	37,286	37,286	32,028	30,994

#### LabPro HVAC Initial Cost Comparison

Cooling Tons Required	Tons	193	193	183	183	163	160
Cooling System Cost	USD	0	0	0	0	0	0
Heating System Cost	USD	0	0	0	0	0	0
Reheat System Cost	USD	0	0	0	0	0	0
Supply AHU Cost	USD	0	0	0	0	0	0
Exhaust Fan Cost	USD	0	0	0	0	0	0
VFD Cost	USD	0	0	0	0	0	0
Duct Cost	USD	0	0	0	0	0	0
Filter Cost	USD	0	0	0	0	0	0
Balancing Cost	USD	9,500	3,800	9,500	3,800	3,800	3,800
ATC Cost	USD	0	0	0	0	0	0
ATC Interface Cost	USD	0	0	0	0	0	0
Lab Controls Cost	USD	0	0	1,050,000	1,050,000	900,000	1,100,000
Hood Certification Cost	USD	2,100	1,050	2,100	1,050	1,050	1,050
<b>Total HVAC Initial Cost</b>	<b>USD</b>	<b>11,600</b>	<b>4,850</b>	<b>1,061,600</b>	<b>1,054,850</b>	<b>904,850</b>	<b>1,104,850</b>
HVAC Initial Cost per Avg Flow	USD/CFM	0.27	0.11	28.47	28.29	28.25	35.65
HVAC Initial Cost per Fume Hood	USD	276.19	115.48	25,276.19	25,115.48	21,544.05	26,305.95
HVAC Initial Cost per Unit Area	USD/Sq. Ft	0.68	0.28	62.21	61.82	53.03	64.75

#### LabPro Energy Cost Comparison (annual)

Annual Cooling Energy Cost	USD	20,045	20,045	17,893	17,893	15,482	15,010
Annual Heating Energy Cost	USD	9,381	9,381	8,069	8,069	6,818	6,571
Annual Reheat Energy Cost	USD	43,190	43,190	34,060	34,060	24,738	22,905
Annual Supply AHU Energy Cost	USD	34,279	34,279	24,170	24,170	18,584	17,360
Annual Exhaust Fan Energy Cost	USD	34,128	34,128	29,986	29,986	25,758	24,926
<b>Total Annual Energy Cost</b>	<b>USD</b>	<b>141,023</b>	<b>141,023</b>	<b>114,179</b>	<b>114,179</b>	<b>91,380</b>	<b>86,771</b>
Annual Energy Cost per Average Flow	USD/CFM	3.32	3.32	3.06	3.06	2.85	2.80
Annual Energy Cost per Fume Hood	USD	3,357.69	3,357.69	2,718.54	2,718.54	2,175.72	2,065.98
Annual Energy Cost per Unit Area	USD/Sq. Ft	8.26	8.26	6.69	6.69	5.36	5.09

#### LabPro Operation and Maintenance Cost Comparison (annual)

Annual Energy Cost	USD	141,023	141,023	114,179	114,179	91,380	86,771
Annual Balancing Cost	USD	9,500	3,800	9,500	3,800	3,800	3,800
Annual Hood Certification Cost	USD	2,100	1,050	2,100	1,050	1,050	1,050
Annual Lab Controls Maintenance Cost	USD	12,600	0	31,500	0	0	0
Annual ATC Maintenance Cost	USD	19,000	19,000	19,000	19,000	19,000	19,000
Annual Filter Cost	USD	0	0	0	0	0	0
Annual Downtime Cost	USD	2,520	0	6,300	0	0	0
<b>Total Annual O&amp;M Costs</b>	<b>USD</b>	<b>186,743</b>	<b>164,873</b>	<b>182,579</b>	<b>138,029</b>	<b>115,230</b>	<b>110,621</b>
Annual O&M Cost per Average Flow	USD/CFM	4.40	3.89	4.90	3.70	3.60	3.57
Annual O&M Cost per Fume Hood	USD	4,446.26	3,925.55	4,347.11	3,286.40	2,743.58	2,633.84
Annual O&M Cost per Unit Area	USD/Sq. Ft	10.94	9.66	10.70	8.09	6.75	6.48

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 1

Room Name 005

ACH Flow (Occupied)	350 CFM
ACH Flow (Unoccupied)	350 CFM
Maximum Cooling Flow	330 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	350		0		0		0	=	0		0		350	350
Demand	0		0		0		0	=	0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	350		0		0		0	=	0		0		350	350
Demand	0		0		0		0	=	0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	350		0		0		0	=	0		0		350	350
Demand	0		0		0		0	=	0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	350		0		0		0	=	0		0		350	350
Demand	0		0		0		0	=	0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 2

Room Name 006

ACH Flow (Occupied)	35 CFM
ACH Flow (Unoccupied)	35 CFM
Maximum Cooling Flow	200 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A Hood	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
	35		0		0		0		0		0		35	35
Demand	0		0		0		0		0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A UnOcc Vent	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
	35		0		0		0		0		0		35	35
Demand	0		0		0		0		0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A Occ Vent	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
	35		0		0		0		0		0		35	35
Demand	0		0		0		0		0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A Thermal	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
	200		0		0		0		0		0		200	200
Demand	0		0		0		0		0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 3

Room Name 007

ACH Flow (Occupied)	840 CFM
ACH Flow (Unoccupied)	840 CFM
Maximum Cooling Flow	590 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	590		250		0		0	=	0		75		765	840
Demand	0		250		0		0	=	0		75		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	590		250		0		0	=	0		75		765	840
Demand	0		250		0		0	=	0		75		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	590		250		0		0	=	0		75		765	840
Demand	0		250		0		0	=	0		75		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	590		250		0		0	=	0		75		765	840
Demand	0		250		0		0	=	0		75		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 4

Room Name 008

ACH Flow (Occupied)	550 CFM
ACH Flow (Unoccupied)	550 CFM
Maximum Cooling Flow	570 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A Hood	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
	1,910		125		0		0		2,000		0		35	2,035
Demand	0		125		0		0		2,000		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A UnOcc Vent	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
	560		125		0		0		650		0		35	685
Demand	0		125		0		0		650		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A Occ Vent	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
	560		125		0		0		650		0		35	685
Demand	0		125		0		0		650		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A Thermal	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
	570		125		0		0		650		0		45	695
Demand	0		125		0		0		650		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 5

Room Name 009

ACH Flow (Occupied)	880 CFM
ACH Flow (Unoccupied)	880 CFM
Maximum Cooling Flow	755 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	755		125		0		0	=	0		75		805	880
Demand	0		125		0		0	=	0		75		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	755		125		0		0	=	0		75		805	880
Demand	0		125		0		0	=	0		75		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	755		125		0		0	=	0		75		805	880
Demand	0		125		0		0	=	0		75		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	755		125		0		0	=	0		75		805	880
Demand	0		125		0		0	=	0		75		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 6

Room Name 011

ACH Flow (Occupied)	90 CFM
ACH Flow (Unoccupied)	90 CFM
Maximum Cooling Flow	600 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A Hood	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
	90		0		0		0		0		0		90	90
Demand	0		0		0		0		0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A UnOcc Vent	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
	90		0		0		0		0		0		90	90
Demand	0		0		0		0		0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A Occ Vent	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
	90		0		0		0		0		0		90	90
Demand	0		0		0		0		0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A Thermal	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
	600		0		0		0		0		0		600	600
Demand	0		0		0		0		0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM



Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 7

Room Name 012

ACH Flow (Occupied)	60 CFM
ACH Flow (Unoccupied)	60 CFM
Maximum Cooling Flow	500 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	60		0		0		0	=	0		0		60	60
Demand	0		0		0		0	=	0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	60		0		0		0	=	0		0		60	60
Demand	0		0		0		0	=	0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	60		0		0		0	=	0		0		60	60
Demand	0		0		0		0	=	0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	500		0		0		0	=	0		0		500	500
Demand	0		0		0		0	=	0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 8

Room Name 013

ACH Flow (Occupied)	40 CFM
ACH Flow (Unoccupied)	40 CFM
Maximum Cooling Flow	300 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	40		0		0		0	=	0		0		40	40
Demand	0		0		0		0	=	0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	40		0		0		0	=	0		0		40	40
Demand	0		0		0		0	=	0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	40		0		0		0	=	0		0		40	40
Demand	0		0		0		0	=	0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	300		0		0		0	=	0		0		300	300
Demand	0		0		0		0	=	0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 9

Room Name 014

ACH Flow (Occupied)	35 CFM
ACH Flow (Unoccupied)	35 CFM
Maximum Cooling Flow	150 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	35		0		0		0	=	0		0		35	35
Demand	0		0		0		0	=	0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	35		0		0		0	=	0		0		35	35
Demand	0		0		0		0	=	0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	35		0		0		0	=	0		0		35	35
Demand	0		0		0		0	=	0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	150		0		0		0	=	0		0		150	150
Demand	0		0		0		0	=	0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 10

Room Name 015

ACH Flow (Occupied)	35 CFM
ACH Flow (Unoccupied)	35 CFM
Maximum Cooling Flow	150 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	35		0		0		0	=	0		0		35	35
Demand	0		0		0		0	=	0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	35		0		0		0	=	0		0		35	35
Demand	0		0		0		0	=	0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	35		0		0		0	=	0		0		35	35
Demand	0		0		0		0	=	0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	150		0		0		0	=	0		0		150	150
Demand	0		0		0		0	=	0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 11

Room Name 016

ACH Flow (Occupied)	40 CFM
ACH Flow (Unoccupied)	40 CFM
Maximum Cooling Flow	300 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A Hood	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
	40		0		0		0		0		0		40	40
Demand	0		0		0		0		0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A UnOcc Vent	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
	40		0		0		0		0		0		40	40
Demand	0		0		0		0		0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A Occ Vent	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
	40		0		0		0		0		0		40	40
Demand	0		0		0		0		0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A Thermal	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
	300		0		0		0		0		0		300	300
Demand	0		0		0		0		0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 12

Room Name 017

ACH Flow (Occupied)	100 CFM
ACH Flow (Unoccupied)	100 CFM
Maximum Cooling Flow	0 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	150		0		0		0	=	0		150		0	150
Demand	0		0		0		0	=	0		150		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	150		0		0		0	=	0		150		0	150
Demand	0		0		0		0	=	0		150		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	150		0		0		0	=	0		150		0	150
Demand	0		0		0		0	=	0		150		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	150		0		0		0	=	0		150		0	150
Demand	0		0		0		0	=	0		150		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 13

Room Name 019

ACH Flow (Occupied)	1,350 CFM
ACH Flow (Unoccupied)	1,350 CFM
Maximum Cooling Flow	249 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	475		875		0		0	=	0		0		1,350	1,350
Demand	0		875		0		0	=	0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	475		875		0		0	=	0		0		1,350	1,350
Demand	0		875		0		0	=	0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	475		875		0		0	=	0		0		1,350	1,350
Demand	0		875		0		0	=	0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	475		875		0		0	=	0		0		1,350	1,350
Demand	0		875		0		0	=	0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 14

Room Name 020

ACH Flow (Occupied)	220 CFM
ACH Flow (Unoccupied)	220 CFM
Maximum Cooling Flow	330 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	330		-330		0		0		0		0		0	0
Demand	0		-330		0		0		0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	330		-330		0		0		0		0		0	0
Demand	0		-330		0		0		0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	330		-330		0		0		0		0		0	0
Demand	0		-330		0		0		0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	330		-330		0		0		0		0		0	0
Demand	0		-330		0		0		0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM



Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 15

Room Name 022

ACH Flow (Occupied)	35 CFM
ACH Flow (Unoccupied)	35 CFM
Maximum Cooling Flow	140 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A Hood	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
	35		0		0		0		0		0		35	35
Demand	0		0		0		0		0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A UnOcc Vent	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
	35		0		0		0		0		0		35	35
Demand	0		0		0		0		0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A Occ Vent	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
	35		0		0		0		0		0		35	35
Demand	0		0		0		0		0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A Thermal	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
	140		0		0		0		0		0		140	140
Demand	0		0		0		0		0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 16

Room Name 023

ACH Flow (Occupied)	150 CFM
ACH Flow (Unoccupied)	150 CFM
Maximum Cooling Flow	130 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	135		15		0		0	=	0		0		150	150
Demand	0		15		0		0	=	0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	135		15		0		0	=	0		0		150	150
Demand	0		15		0		0	=	0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	135		15		0		0	=	0		0		150	150
Demand	0		15		0		0	=	0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	135		15		0		0	=	0		0		150	150
Demand	0		15		0		0	=	0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 17

Room Name 024

ACH Flow (Occupied)	35 CFM
ACH Flow (Unoccupied)	35 CFM
Maximum Cooling Flow	350 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	35		0		0		0	=	0		0		35	35
Demand	0		0		0		0	=	0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	35		0		0		0	=	0		0		35	35
Demand	0		0		0		0	=	0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	35		0		0		0	=	0		0		35	35
Demand	0		0		0		0	=	0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	350		0		0		0	=	0		0		350	350
Demand	0		0		0		0	=	0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 18

Room Name 101

ACH Flow (Occupied)	450 CFM
ACH Flow (Unoccupied)	450 CFM
Maximum Cooling Flow	400 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	400		50		0		0		0		0		450	450
Demand	0		50		0		0		0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	400		50		0		0		0		0		450	450
Demand	0		50		0		0		0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	400		50		0		0		0		0		450	450
Demand	0		50		0		0		0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	400		50		0		0		0		0		450	450
Demand	0		50		0		0		0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 19

Room Name 102

ACH Flow (Occupied)	90 CFM
ACH Flow (Unoccupied)	90 CFM
Maximum Cooling Flow	450 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A Hood	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
	90		0		0		0		0		0		90	90
Demand	0		0		0		0		0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A UnOcc Vent	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
	90		0		0		0		0		0		90	90
Demand	0		0		0		0		0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A Occ Vent	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
	90		0		0		0		0		0		90	90
Demand	0		0		0		0		0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A Thermal	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
	450		0		0		0		0		0		450	450
Demand	0		0		0		0		0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 20

Room Name 103

ACH Flow (Occupied)	35 CFM
ACH Flow (Unoccupied)	35 CFM
Maximum Cooling Flow	240 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A Hood	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
	35		0		0		0		0		0		35	35
Demand	0		0		0		0		0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A UnOcc Vent	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
	35		0		0		0		0		0		35	35
Demand	0		0		0		0		0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A Occ Vent	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
	35		0		0		0		0		0		35	35
Demand	0		0		0		0		0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A Thermal	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
	240		0		0		0		0		0		240	240
Demand	0		0		0		0		0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 21

Room Name 103A

ACH Flow (Occupied)	35 CFM
ACH Flow (Unoccupied)	35 CFM
Maximum Cooling Flow	280 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	35		0		0		0		0		0		35	35
Demand	0		0		0		0		0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	35		0		0		0		0		0		35	35
Demand	0		0		0		0		0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	35		0		0		0		0		0		35	35
Demand	0		0		0		0		0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	280		0		0		0		0		0		280	280
Demand	0		0		0		0		0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 22

Room Name 104

ACH Flow (Occupied)	125 CFM
ACH Flow (Unoccupied)	125 CFM
Maximum Cooling Flow	0 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	0		125		0		0	=	0		0		125	125
Demand	0		125		0		0	=	0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	0		125		0		0	=	0		0		125	125
Demand	0		125		0		0	=	0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	0		125		0		0	=	0		0		125	125
Demand	0		125		0		0	=	0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	0		125		0		0	=	0		0		125	125
Demand	0		125		0		0	=	0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM



Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 23

Room Name 105

ACH Flow (Occupied)	75 CFM
ACH Flow (Unoccupied)	75 CFM
Maximum Cooling Flow	140 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	75		0		0		0	=	0		0		75	75
Demand	0		0		0		0	=	0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	75		0		0		0	=	0		0		75	75
Demand	0		0		0		0	=	0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	75		0		0		0	=	0		0		75	75
Demand	0		0		0		0	=	0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	140		0		0		0	=	0		0		140	140
Demand	0		0		0		0	=	0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 24

Room Name 106

ACH Flow (Occupied)	75 CFM
ACH Flow (Unoccupied)	75 CFM
Maximum Cooling Flow	430 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A Hood	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
	75		0		0		0		0		0		75	75
Demand	0		0		0		0		0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A UnOcc Vent	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
	75		0		0		0		0		0		75	75
Demand	0		0		0		0		0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A Occ Vent	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
	75		0		0		0		0		0		75	75
Demand	0		0		0		0		0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A Thermal	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
	430		0		0		0		0		0		430	430
Demand	0		0		0		0		0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 25

Room Name 107

ACH Flow (Occupied)	330 CFM
ACH Flow (Unoccupied)	330 CFM
Maximum Cooling Flow	499 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	4,745		250		0		0		4,800		195		0	4,995
Demand	0		250		0		0		4,800		195		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	2,545		250		0		0		2,600		195		0	2,795
Demand	0		250		0		0		2,600		195		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	2,545		250		0		0		2,600		195		0	2,795
Demand	0		250		0		0		2,600		195		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	2,545		250		0		0		2,600		195		0	2,795
Demand	0		250		0		0		2,600		195		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 26

Room Name 108

ACH Flow (Occupied)	781 CFM
ACH Flow (Unoccupied)	781 CFM
Maximum Cooling Flow	1,100 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	706		75		0		0	=	0		0		781	781
Demand	0		75		0		0	=	0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	706		75		0		0	=	0		0		781	781
Demand	0		75		0		0	=	0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	706		75		0		0	=	0		0		781	781
Demand	0		75		0		0	=	0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	1,100		75		0		0	=	0		0		1,175	1,175
Demand	0		75		0		0	=	0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 27

Room Name 109

ACH Flow (Occupied)	1,426 CFM
ACH Flow (Unoccupied)	1,426 CFM
Maximum Cooling Flow	2,340 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	5

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	5,070		250		555		0		5,625		75		175	5,875
Demand	4,545		250		1,080		0		5,625		75		175	5,875
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	2,370		250		555		0		2,925		75		175	3,175
Demand	1,845		250		1,080		0		2,925		75		175	3,175
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	2,370		250		555		0		2,925		75		175	3,175
Demand	1,845		250		1,080		0		2,925		75		175	3,175
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	2,370		250		555		0		2,925		75		175	3,175
Demand	2,340		250		1,080		0		2,925		75		670	3,670
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 28

Room Name 120

ACH Flow (Occupied)	385 CFM
ACH Flow (Unoccupied)	385 CFM
Maximum Cooling Flow	385 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	385		-385		0		0	=	0		0		0	0
Demand	0		-385		0		0	=	0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	385		-385		0		0	=	0		0		0	0
Demand	0		-385		0		0	=	0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	385		-385		0		0	=	0		0		0	0
Demand	0		-385		0		0	=	0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	385		-385		0		0	=	0		0		0	0
Demand	0		-385		0		0	=	0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 29

Room Name 201

ACH Flow (Occupied)	35 CFM
ACH Flow (Unoccupied)	35 CFM
Maximum Cooling Flow	360 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	35		0		0		0	=	0		0		35	35
Demand	0		0		0		0	=	0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	35		0		0		0	=	0		0		35	35
Demand	0		0		0		0	=	0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	35		0		0		0	=	0		0		35	35
Demand	0		0		0		0	=	0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	360		0		0		0	=	0		0		360	360
Demand	0		0		0		0	=	0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 30

Room Name 202

ACH Flow (Occupied)	525 CFM
ACH Flow (Unoccupied)	525 CFM
Maximum Cooling Flow	1,175 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	900		125		0		0		750		225		50	1,025
Demand	0		125		0		0		750		225		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	400		125		0		0		150		225		150	525
Demand	0		125		0		0		150		225		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	400		125		0		0		150		225		150	525
Demand	0		125		0		0		150		225		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	1,175		125		0		0		150		225		925	1,300
Demand	0		125		0		0		150		225		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM



Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 31

Room Name 203

ACH Flow (Occupied)	1,925 CFM
ACH Flow (Unoccupied)	1,925 CFM
Maximum Cooling Flow	615 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	1,810		115		0		0		1,500		425		0	1,925
Demand	0		115		0		0		1,500		425		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	1,810		115		0		0		1,500		425		0	1,925
Demand	0		115		0		0		1,500		425		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	1,810		115		0		0		1,500		425		0	1,925
Demand	0		115		0		0		1,500		425		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	1,810		115		0		0		1,500		425		0	1,925
Demand	0		115		0		0		1,500		425		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 32

Room Name 204

ACH Flow (Occupied)	50 CFM
ACH Flow (Unoccupied)	50 CFM
Maximum Cooling Flow	450 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	50		0		0		0	=	0		0		50	50
Demand	0		0		0		0	=	0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	50		0		0		0	=	0		0		50	50
Demand	0		0		0		0	=	0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	50		0		0		0	=	0		0		50	50
Demand	0		0		0		0	=	0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	450		0		0		0	=	0		0		450	450
Demand	0		0		0		0	=	0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 33

Room Name 205

ACH Flow (Occupied)	450 CFM
ACH Flow (Unoccupied)	450 CFM
Maximum Cooling Flow	450 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	450		0		0		0	=	0		0		450	450
Demand	0		0		0		0	=	0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	450		0		0		0	=	0		0		450	450
Demand	0		0		0		0	=	0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	450		0		0		0	=	0		0		450	450
Demand	0		0		0		0	=	0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	450		0		0		0	=	0		0		450	450
Demand	0		0		0		0	=	0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 34

Room Name 206

ACH Flow (Occupied)	879 CFM
ACH Flow (Unoccupied)	878 CFM
Maximum Cooling Flow	2,875 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	3,275		125		0		0		2,915		450		35	3,400
Demand	0		125		0		0		2,915		450		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	2,295		125		0		0		1,935		450		35	2,420
Demand	0		125		0		0		1,935		450		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	2,295		125		0		0		1,935		450		35	2,420
Demand	0		125		0		0		1,935		450		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	2,875		125		0		0		1,935		450		615	3,000
Demand	0		125		0		0		1,935		450		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 35

Room Name 207

ACH Flow (Occupied)	1,114 CFM
ACH Flow (Unoccupied)	1,114 CFM
Maximum Cooling Flow	2,445 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A Hood	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
	3,070		125		0		0		3,160		0		35	3,195
Demand	0		125		0		0		3,160		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A UnOcc Vent	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
	1,845		125		0		0		1,935		0		35	1,970
Demand	0		125		0		0		1,935		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A Occ Vent	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
	1,845		125		0		0		1,935		0		35	1,970
Demand	0		125		0		0		1,935		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A Thermal	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
	2,445		125		0		0		1,935		0		635	2,570
Demand	0		125		0		0		1,935		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 36

Room Name 208

ACH Flow (Occupied)	557 CFM
ACH Flow (Unoccupied)	557 CFM
Maximum Cooling Flow	2,470 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A Hood	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
	3,125		125		0		0		3,140		75		35	3,250
Demand	0		125		0		0		3,140		75		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A UnOcc Vent	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
	1,920		125		0		0		1,935		75		35	2,045
Demand	0		125		0		0		1,935		75		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A Occ Vent	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
	1,920		125		0		0		1,935		75		35	2,045
Demand	0		125		0		0		1,935		75		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A Thermal	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
	2,470		125		0		0		1,935		75		585	2,595
Demand	0		125		0		0		1,935		75		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 37

Room Name 209

ACH Flow (Occupied)	878 CFM
ACH Flow (Unoccupied)	878 CFM
Maximum Cooling Flow	1,855 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	4,200		125		0		0		4,325		0		0	4,325
Demand	0		125		0		0		4,325		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	3,000		125		0		0		3,125		0		0	3,125
Demand	0		125		0		0		3,125		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	3,000		125		0		0		3,125		0		0	3,125
Demand	0		125		0		0		3,125		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	3,000		125		0		0		3,125		0		0	3,125
Demand	0		125		0		0		3,125		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 38

Room Name 220

ACH Flow (Occupied)	375 CFM
ACH Flow (Unoccupied)	375 CFM
Maximum Cooling Flow	375 CFM
CV Supply Quantity	0
VAV Supply Quantity	1
VAV GEX Quantity	1

Condition	Supply				=	Exhaust			Total					
1A	Supply 1A	+	Offset	+	Office Min	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1A	Total Exhaust 1A
Hood	375		-375		0		0	=	0		0		0	0
Demand	0		-375		0		0	=	0		0		0	0
1B*	Supply 1B	+	Offset	+	Office Max	+	CV Supply	=	Hood Max	+	Other Exh. Max	+	GEX 1B	Total Exhaust 1B
2A	Supply 2A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2A	Total Exhaust 2A
UnOcc Vent	375		-375		0		0	=	0		0		0	0
Demand	0		-375		0		0	=	0		0		0	0
2B*	Supply 2B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 2B	Total Exhaust 2B
3A	Supply 3A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3A	Total Exhaust 3A
Occ Vent	375		-375		0		0	=	0		0		0	0
Demand	0		-375		0		0	=	0		0		0	0
3B*	Supply 3B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 3B	Total Exhaust 3B
4A	Supply 4A	+	Offset	+	Office Min	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4A	Total Exhaust 4A
Thermal	375		-375		0		0	=	0		0		0	0
Demand	0		-375		0		0	=	0		0		0	0
4B*	Supply 4B	+	Offset	+	Office Max	+	CV Supply	=	Hood Min	+	Other Exh. Min	+	GEX 4B	Total Exhaust 4B

\* If Applicable

Flow Unit: CFM



Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 1

Room Name 005  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Positive	
Calc Max Cooling Flow?	No	
Max Cooling Flow	330	CFM
Room Area	288.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	3,168	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	7	
Occupied ACH Flow	350	CFM
Unoccupied ACH	7	
Unoccupied ACH Flow	350	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	0	CFM
Fixed Offset Flow	0	CFM

Hood Count	0	
Hood Max Flow	0	CFM
Hood Min Flow	0	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	350	CFM
GEX Min Flow	350	CFM
Other Exhaust Max Flow	0	CFM
Other Exhaust Min Flow	0	CFM
Total Exhaust Max Flow	350	CFM
Total Exhaust Min Flow	350	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	350	CFM
Supply Min Flow	350	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	142	9:00 AM	317	5:00 PM	330
2:00 AM	142	10:00 AM	317	6:00 PM	264
3:00 AM	139	11:00 AM	317	7:00 PM	152
4:00 AM	139	Noon	251	8:00 PM	152
5:00 AM	139	1:00 PM	320	9:00 PM	152
6:00 AM	135	2:00 PM	323	10:00 PM	149
7:00 AM	248	3:00 PM	327	11:00 PM	145
8:00 AM	317	4:00 PM	327	Midnight	145

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 2

Room Name 006  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Positive	
Calc Max Cooling Flow?	No	
Max Cooling Flow	200	CFM
Room Area	175.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	1,926	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	1	
Occupied ACH Flow	35	CFM
Unoccupied ACH	1	
Unoccupied ACH Flow	35	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	0	CFM
Fixed Offset Flow	0	CFM

Hood Count	0	
Hood Max Flow	0	CFM
Hood Min Flow	0	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	200	CFM
GEX Min Flow	35	CFM
Other Exhaust Max Flow	0	CFM
Other Exhaust Min Flow	0	CFM
Total Exhaust Max Flow	200	CFM
Total Exhaust Min Flow	35	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	200	CFM
Supply Min Flow	35	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	86	9:00 AM	192	5:00 PM	200
2:00 AM	86	10:00 AM	192	6:00 PM	160
3:00 AM	84	11:00 AM	192	7:00 PM	92
4:00 AM	84	Noon	152	8:00 PM	92
5:00 AM	84	1:00 PM	194	9:00 PM	92
6:00 AM	82	2:00 PM	196	10:00 PM	90
7:00 AM	150	3:00 PM	198	11:00 PM	88
8:00 AM	192	4:00 PM	198	Midnight	88

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 3

Room Name 007  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Negative	
Calc Max Cooling Flow?	No	
Max Cooling Flow	590	CFM
Room Area	470.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	5,170	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	10	
Occupied ACH Flow	840	CFM
Unoccupied ACH	10	
Unoccupied ACH Flow	840	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	250	CFM
Fixed Offset Flow	250	CFM

Hood Count	0	
Hood Max Flow	0	CFM
Hood Min Flow	0	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	765	CFM
GEX Min Flow	765	CFM
Other Exhaust Max Flow	75	CFM
Other Exhaust Min Flow	75	CFM
Total Exhaust Max Flow	840	CFM
Total Exhaust Min Flow	840	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	590	CFM
Supply Min Flow	590	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	254	9:00 AM	566	5:00 PM	590
2:00 AM	254	10:00 AM	566	6:00 PM	472
3:00 AM	248	11:00 AM	566	7:00 PM	271
4:00 AM	248	Noon	448	8:00 PM	271
5:00 AM	248	1:00 PM	572	9:00 PM	271
6:00 AM	242	2:00 PM	578	10:00 PM	266
7:00 AM	443	3:00 PM	584	11:00 PM	260
8:00 AM	566	4:00 PM	584	Midnight	260

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 4

Room Name 008  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Negative	
Calc Max Cooling Flow?	No	
Max Cooling Flow	570	CFM
Room Area	500.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	5,500	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	6	
Occupied ACH Flow	550	CFM
Unoccupied ACH	6	
Unoccupied ACH Flow	550	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	125	CFM
Fixed Offset Flow	125	CFM

Hood Count	2	
Hood Max Flow	2,000	CFM
Hood Min Flow	650	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	45	CFM
GEX Min Flow	35	CFM
Other Exhaust Max Flow	0	CFM
Other Exhaust Min Flow	0	CFM
Total Exhaust Max Flow	2,035	CFM
Total Exhaust Min Flow	685	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	1,910	CFM
Supply Min Flow	560	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	245	9:00 AM	547	5:00 PM	570
2:00 AM	245	10:00 AM	547	6:00 PM	456
3:00 AM	239	11:00 AM	547	7:00 PM	262
4:00 AM	239	Noon	433	8:00 PM	262
5:00 AM	239	1:00 PM	553	9:00 PM	262
6:00 AM	234	2:00 PM	559	10:00 PM	257
7:00 AM	428	3:00 PM	564	11:00 PM	251
8:00 AM	547	4:00 PM	564	Midnight	251

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 5

Room Name 009  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Negative		Hood Count	0	
Calc Max Cooling Flow?	No		Hood Max Flow	0	CFM
Max Cooling Flow	755		Hood Min Flow	0	CFM
		CFM	Office Max Flow	0	CFM
Room Area	565.00	Sq. Ft	Office Min Flow	0	CFM
Ceiling Height	11.00	Ft	GEX Type	VAV	
Room Volume	6,216	Cubic Feet	GEX Valve Quantity	1	
Room Temp Set Point	74	Deg F	GEX Max Flow	805	CFM
Heat Gain	10	Watts/Sq. Ft	GEX Min Flow	805	CFM
Occupied ACH	8		Other Exhaust Max Flow	75	CFM
Occupied ACH Flow	880	CFM	Other Exhaust Min Flow	75	CFM
Unoccupied ACH	8		Total Exhaust Max Flow	880	CFM
Unoccupied ACH Flow	880	CFM	Total Exhaust Min Flow	880	CFM
Offset Option	10% upto fixed offset flow		Supply Type	VAV	
Offset Flow	125	CFM	Supply Valve Quantity	1	
Fixed Offset Flow	125	CFM	Supply Max Flow	755	CFM
			Supply Min Flow	755	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	325	9:00 AM	725	5:00 PM	755
2:00 AM	325	10:00 AM	725	6:00 PM	604
3:00 AM	317	11:00 AM	725	7:00 PM	347
4:00 AM	317	Noon	574	8:00 PM	347
5:00 AM	317	1:00 PM	732	9:00 PM	347
6:00 AM	310	2:00 PM	740	10:00 PM	340
7:00 AM	566	3:00 PM	747	11:00 PM	332
8:00 AM	725	4:00 PM	747	Midnight	332

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 6

Room Name 011  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Positive		Hood Count	0	
Calc Max Cooling Flow?	No		Hood Max Flow	0	CFM
Max Cooling Flow	600		Hood Min Flow	0	CFM
		CFM	Office Max Flow	0	CFM
Room Area	589.00	Sq. Ft	Office Min Flow	0	CFM
Ceiling Height	11.00	Ft	GEX Type	VAV	
Room Volume	6,480	Cubic Feet	GEX Valve Quantity	1	
Room Temp Set Point	74	Deg F	GEX Max Flow	600	CFM
Heat Gain	10	Watts/Sq. Ft	GEX Min Flow	90	CFM
Occupied ACH	1		Other Exhaust Max Flow	0	CFM
Occupied ACH Flow	90	CFM	Other Exhaust Min Flow	0	CFM
Unoccupied ACH	1		Total Exhaust Max Flow	600	CFM
Unoccupied ACH Flow	90	CFM	Total Exhaust Min Flow	90	CFM
Offset Option	10% upto fixed offset flow		Supply Type	VAV	
Offset Flow	0	CFM	Supply Valve Quantity	1	
Fixed Offset Flow	0	CFM	Supply Max Flow	600	CFM
			Supply Min Flow	90	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	258	9:00 AM	576	5:00 PM	600
2:00 AM	258	10:00 AM	576	6:00 PM	480
3:00 AM	252	11:00 AM	576	7:00 PM	276
4:00 AM	252	Noon	456	8:00 PM	276
5:00 AM	252	1:00 PM	582	9:00 PM	276
6:00 AM	246	2:00 PM	588	10:00 PM	270
7:00 AM	450	3:00 PM	594	11:00 PM	264
8:00 AM	576	4:00 PM	594	Midnight	264

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 7

Room Name 012  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Positive		Hood Count	0	
Calc Max Cooling Flow?	No		Hood Max Flow	0	CFM
Max Cooling Flow	500		Hood Min Flow	0	CFM
		CFM	Office Max Flow	0	CFM
Room Area	377.00	Sq. Ft	Office Min Flow	0	CFM
Ceiling Height	11.00	Ft	GEX Type	VAV	
Room Volume	4,148	Cubic Feet	GEX Valve Quantity	1	
Room Temp Set Point	74	Deg F	GEX Max Flow	500	CFM
Heat Gain	10	Watts/Sq. Ft	GEX Min Flow	60	CFM
Occupied ACH	1		Other Exhaust Max Flow	0	CFM
Occupied ACH Flow	60	CFM	Other Exhaust Min Flow	0	CFM
Unoccupied ACH	1		Total Exhaust Max Flow	500	CFM
Unoccupied ACH Flow	60	CFM	Total Exhaust Min Flow	60	CFM
Offset Option	10% upto fixed offset flow		Supply Type	VAV	
Offset Flow	0	CFM	Supply Valve Quantity	1	
Fixed Offset Flow	0	CFM	Supply Max Flow	500	CFM
			Supply Min Flow	60	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	215	9:00 AM	480	5:00 PM	500
2:00 AM	215	10:00 AM	480	6:00 PM	400
3:00 AM	210	11:00 AM	480	7:00 PM	230
4:00 AM	210	Noon	380	8:00 PM	230
5:00 AM	210	1:00 PM	485	9:00 PM	230
6:00 AM	205	2:00 PM	490	10:00 PM	225
7:00 AM	375	3:00 PM	495	11:00 PM	220
8:00 AM	480	4:00 PM	495	Midnight	220

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 8

Room Name 013  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Positive	
Calc Max Cooling Flow?	No	
Max Cooling Flow	300	CFM
Room Area	256.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	2,816	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	1	
Occupied ACH Flow	40	CFM
Unoccupied ACH	1	
Unoccupied ACH Flow	40	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	0	CFM
Fixed Offset Flow	0	CFM

Hood Count	0	
Hood Max Flow	0	CFM
Hood Min Flow	0	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	300	CFM
GEX Min Flow	40	CFM
Other Exhaust Max Flow	0	CFM
Other Exhaust Min Flow	0	CFM
Total Exhaust Max Flow	300	CFM
Total Exhaust Min Flow	40	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	300	CFM
Supply Min Flow	40	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	129	9:00 AM	288	5:00 PM	300
2:00 AM	129	10:00 AM	288	6:00 PM	240
3:00 AM	126	11:00 AM	288	7:00 PM	138
4:00 AM	126	Noon	228	8:00 PM	138
5:00 AM	126	1:00 PM	291	9:00 PM	138
6:00 AM	123	2:00 PM	294	10:00 PM	135
7:00 AM	225	3:00 PM	297	11:00 PM	132
8:00 AM	288	4:00 PM	297	Midnight	132



Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 9

Room Name 014  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Positive		Hood Count	0	
Calc Max Cooling Flow?	No		Hood Max Flow	0	CFM
Max Cooling Flow	150		Hood Min Flow	0	CFM
		CFM	Office Max Flow	0	CFM
Room Area	138.00	Sq. Ft	Office Min Flow	0	CFM
Ceiling Height	11.00	Ft	GEX Type	VAV	
Room Volume	1,518	Cubic Feet	GEX Valve Quantity	1	
Room Temp Set Point	74	Deg F	GEX Max Flow	150	CFM
Heat Gain	10	Watts/Sq. Ft	GEX Min Flow	35	CFM
Occupied ACH	1		Other Exhaust Max Flow	0	CFM
Occupied ACH Flow	35	CFM	Other Exhaust Min Flow	0	CFM
Unoccupied ACH	1		Total Exhaust Max Flow	150	CFM
Unoccupied ACH Flow	35	CFM	Total Exhaust Min Flow	35	CFM
Offset Option	10% upto fixed offset flow		Supply Type	VAV	
Offset Flow	0	CFM	Supply Valve Quantity	1	
Fixed Offset Flow	0	CFM	Supply Max Flow	150	CFM
			Supply Min Flow	35	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	65	9:00 AM	144	5:00 PM	150
2:00 AM	65	10:00 AM	144	6:00 PM	120
3:00 AM	63	11:00 AM	144	7:00 PM	69
4:00 AM	63	Noon	114	8:00 PM	69
5:00 AM	63	1:00 PM	146	9:00 PM	69
6:00 AM	62	2:00 PM	147	10:00 PM	68
7:00 AM	113	3:00 PM	149	11:00 PM	66
8:00 AM	144	4:00 PM	149	Midnight	66

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 10

Room Name 015  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Positive	
Calc Max Cooling Flow?	No	
Max Cooling Flow	150	CFM
Room Area	138.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	1,518	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	1	
Occupied ACH Flow	35	CFM
Unoccupied ACH	1	
Unoccupied ACH Flow	35	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	0	CFM
Fixed Offset Flow	0	CFM

Hood Count	0	
Hood Max Flow	0	CFM
Hood Min Flow	0	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	150	CFM
GEX Min Flow	35	CFM
Other Exhaust Max Flow	0	CFM
Other Exhaust Min Flow	0	CFM
Total Exhaust Max Flow	150	CFM
Total Exhaust Min Flow	35	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	150	CFM
Supply Min Flow	35	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	65	9:00 AM	144	5:00 PM	150
2:00 AM	65	10:00 AM	144	6:00 PM	120
3:00 AM	63	11:00 AM	144	7:00 PM	69
4:00 AM	63	Noon	114	8:00 PM	69
5:00 AM	63	1:00 PM	146	9:00 PM	69
6:00 AM	62	2:00 PM	147	10:00 PM	68
7:00 AM	113	3:00 PM	149	11:00 PM	66
8:00 AM	144	4:00 PM	149	Midnight	66

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 11

Room Name 016  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Positive	
Calc Max Cooling Flow?	No	
Max Cooling Flow	300	CFM
Room Area	253.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	2,784	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	1	
Occupied ACH Flow	40	CFM
Unoccupied ACH	1	
Unoccupied ACH Flow	40	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	0	CFM
Fixed Offset Flow	0	CFM

Hood Count	0	
Hood Max Flow	0	CFM
Hood Min Flow	0	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	300	CFM
GEX Min Flow	40	CFM
Other Exhaust Max Flow	0	CFM
Other Exhaust Min Flow	0	CFM
Total Exhaust Max Flow	300	CFM
Total Exhaust Min Flow	40	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	300	CFM
Supply Min Flow	40	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	129	9:00 AM	288	5:00 PM	300
2:00 AM	129	10:00 AM	288	6:00 PM	240
3:00 AM	126	11:00 AM	288	7:00 PM	138
4:00 AM	126	Noon	228	8:00 PM	138
5:00 AM	126	1:00 PM	291	9:00 PM	138
6:00 AM	123	2:00 PM	294	10:00 PM	135
7:00 AM	225	3:00 PM	297	11:00 PM	132
8:00 AM	288	4:00 PM	297	Midnight	132

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 12

Room Name 017  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Negative		Hood Count	0	
Calc Max Cooling Flow?	No		Hood Max Flow	0	CFM
Max Cooling Flow	0		Hood Min Flow	0	CFM
		CFM	Office Max Flow	0	CFM
Room Area	150.00	Sq. Ft	Office Min Flow	0	CFM
Ceiling Height	11.00	Ft	GEX Type	VAV	
Room Volume	1,650	Cubic Feet	GEX Valve Quantity	1	
Room Temp Set Point	74	Deg F	GEX Max Flow	0	CFM
Heat Gain	10	Watts/Sq. Ft	GEX Min Flow	0	CFM
Occupied ACH	4		Other Exhaust Max Flow	150	CFM
Occupied ACH Flow	100	CFM	Other Exhaust Min Flow	150	CFM
Unoccupied ACH	4		Total Exhaust Max Flow	150	CFM
Unoccupied ACH Flow	100	CFM	Total Exhaust Min Flow	150	CFM
Offset Option	10% upto fixed offset flow		Supply Type	VAV	
Offset Flow	0	CFM	Supply Valve Quantity	1	
Fixed Offset Flow	0	CFM	Supply Max Flow	150	CFM
			Supply Min Flow	150	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	0	9:00 AM	0	5:00 PM	0
2:00 AM	0	10:00 AM	0	6:00 PM	0
3:00 AM	0	11:00 AM	0	7:00 PM	0
4:00 AM	0	Noon	0	8:00 PM	0
5:00 AM	0	1:00 PM	0	9:00 PM	0
6:00 AM	0	2:00 PM	0	10:00 PM	0
7:00 AM	0	3:00 PM	0	11:00 PM	0
8:00 AM	0	4:00 PM	0	Midnight	0

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 13

Room Name 019  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Negative	
Calc Max Cooling Flow?	No	
Max Cooling Flow	249	CFM
Room Area	150.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	1,650	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	49	
Occupied ACH Flow	1,350	CFM
Unoccupied ACH	49	
Unoccupied ACH Flow	1,350	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	875	CFM
Fixed Offset Flow	875	CFM

Hood Count	0	
Hood Max Flow	0	CFM
Hood Min Flow	0	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	1,350	CFM
GEX Min Flow	1,350	CFM
Other Exhaust Max Flow	0	CFM
Other Exhaust Min Flow	0	CFM
Total Exhaust Max Flow	1,350	CFM
Total Exhaust Min Flow	1,350	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	475	CFM
Supply Min Flow	475	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	107	9:00 AM	239	5:00 PM	249
2:00 AM	107	10:00 AM	239	6:00 PM	199
3:00 AM	105	11:00 AM	239	7:00 PM	115
4:00 AM	105	Noon	189	8:00 PM	115
5:00 AM	105	1:00 PM	242	9:00 PM	115
6:00 AM	102	2:00 PM	244	10:00 PM	112
7:00 AM	187	3:00 PM	247	11:00 PM	110
8:00 AM	239	4:00 PM	247	Midnight	110

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 14

Room Name 020  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Positive	
Calc Max Cooling Flow?	No	
Max Cooling Flow	330	CFM
Room Area	200.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	2,200	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	6	
Occupied ACH Flow	220	CFM
Unoccupied ACH	6	
Unoccupied ACH Flow	220	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	-330	CFM
Fixed Offset Flow	330	CFM

Hood Count	0	
Hood Max Flow	0	CFM
Hood Min Flow	0	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	0	CFM
GEX Min Flow	0	CFM
Other Exhaust Max Flow	0	CFM
Other Exhaust Min Flow	0	CFM
Total Exhaust Max Flow	0	CFM
Total Exhaust Min Flow	0	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	330	CFM
Supply Min Flow	330	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	142	9:00 AM	317	5:00 PM	330
2:00 AM	142	10:00 AM	317	6:00 PM	264
3:00 AM	139	11:00 AM	317	7:00 PM	152
4:00 AM	139	Noon	251	8:00 PM	152
5:00 AM	139	1:00 PM	320	9:00 PM	152
6:00 AM	135	2:00 PM	323	10:00 PM	149
7:00 AM	248	3:00 PM	327	11:00 PM	145
8:00 AM	317	4:00 PM	327	Midnight	145

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 15

Room Name 022  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Negative	
Calc Max Cooling Flow?	No	
Max Cooling Flow	140	CFM
Room Area	300.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	3,300	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	1	
Occupied ACH Flow	35	CFM
Unoccupied ACH	1	
Unoccupied ACH Flow	35	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	0	CFM
Fixed Offset Flow	0	CFM

Hood Count	0	
Hood Max Flow	0	CFM
Hood Min Flow	0	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	140	CFM
GEX Min Flow	35	CFM
Other Exhaust Max Flow	0	CFM
Other Exhaust Min Flow	0	CFM
Total Exhaust Max Flow	140	CFM
Total Exhaust Min Flow	35	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	140	CFM
Supply Min Flow	35	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	60	9:00 AM	134	5:00 PM	140
2:00 AM	60	10:00 AM	134	6:00 PM	112
3:00 AM	59	11:00 AM	134	7:00 PM	64
4:00 AM	59	Noon	106	8:00 PM	64
5:00 AM	59	1:00 PM	136	9:00 PM	64
6:00 AM	57	2:00 PM	137	10:00 PM	63
7:00 AM	105	3:00 PM	139	11:00 PM	62
8:00 AM	134	4:00 PM	139	Midnight	62

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 16

Room Name 023  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Negative		Hood Count	0	
Calc Max Cooling Flow?	No		Hood Max Flow	0	CFM
Max Cooling Flow	130		Hood Min Flow	0	CFM
		CFM	Office Max Flow	0	CFM
Room Area	100.00	Sq. Ft	Office Min Flow	0	CFM
Ceiling Height	11.00	Ft	GEX Type	VAV	
Room Volume	1,100	Cubic Feet	GEX Valve Quantity	1	
Room Temp Set Point	74	Deg F	GEX Max Flow	150	CFM
Heat Gain	10	Watts/Sq. Ft	GEX Min Flow	150	CFM
Occupied ACH	8		Other Exhaust Max Flow	0	CFM
Occupied ACH Flow	150	CFM	Other Exhaust Min Flow	0	CFM
Unoccupied ACH	8		Total Exhaust Max Flow	150	CFM
Unoccupied ACH Flow	150	CFM	Total Exhaust Min Flow	150	CFM
Offset Option	10%		Supply Type	VAV	
Offset Flow	15	CFM	Supply Valve Quantity	1	
Fixed Offset Flow	0	CFM	Supply Max Flow	135	CFM
			Supply Min Flow	135	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	56	9:00 AM	125	5:00 PM	130
2:00 AM	56	10:00 AM	125	6:00 PM	104
3:00 AM	55	11:00 AM	125	7:00 PM	60
4:00 AM	55	Noon	99	8:00 PM	60
5:00 AM	55	1:00 PM	126	9:00 PM	60
6:00 AM	53	2:00 PM	127	10:00 PM	59
7:00 AM	98	3:00 PM	129	11:00 PM	57
8:00 AM	125	4:00 PM	129	Midnight	57



Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 17

Room Name 024  
 Room Description Electrical  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Negative	
Calc Max Cooling Flow?	No	
Max Cooling Flow	350	CFM
Room Area	200.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	2,200	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	1	
Occupied ACH Flow	35	CFM
Unoccupied ACH	1	
Unoccupied ACH Flow	35	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	0	CFM
Fixed Offset Flow	0	CFM

Hood Count	0	
Hood Max Flow	0	CFM
Hood Min Flow	0	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	350	CFM
GEX Min Flow	35	CFM
Other Exhaust Max Flow	0	CFM
Other Exhaust Min Flow	0	CFM
Total Exhaust Max Flow	350	CFM
Total Exhaust Min Flow	35	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	350	CFM
Supply Min Flow	35	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	151	9:00 AM	336	5:00 PM	350
2:00 AM	151	10:00 AM	336	6:00 PM	280
3:00 AM	147	11:00 AM	336	7:00 PM	161
4:00 AM	147	Noon	266	8:00 PM	161
5:00 AM	147	1:00 PM	340	9:00 PM	161
6:00 AM	144	2:00 PM	343	10:00 PM	158
7:00 AM	263	3:00 PM	347	11:00 PM	154
8:00 AM	336	4:00 PM	347	Midnight	154

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 18

Room Name 101  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Negative		Hood Count	0	
Calc Max Cooling Flow?	No		Hood Max Flow	0	CFM
Max Cooling Flow	400		Hood Min Flow	0	CFM
		CFM	Office Max Flow	0	CFM
Room Area	300.00	Sq. Ft	Office Min Flow	0	CFM
Ceiling Height	11.00	Ft	GEX Type	VAV	
Room Volume	3,300	Cubic Feet	GEX Valve Quantity	1	
Room Temp Set Point	74	Deg F	GEX Max Flow	450	CFM
Heat Gain	10	Watts/Sq. Ft	GEX Min Flow	450	CFM
Occupied ACH	8		Other Exhaust Max Flow	0	CFM
Occupied ACH Flow	450	CFM	Other Exhaust Min Flow	0	CFM
Unoccupied ACH	8		Total Exhaust Max Flow	450	CFM
Unoccupied ACH Flow	450	CFM	Total Exhaust Min Flow	450	CFM
Offset Option	10% upto fixed offset flow		Supply Type	VAV	
Offset Flow	50	CFM	Supply Valve Quantity	1	
Fixed Offset Flow	50	CFM	Supply Max Flow	400	CFM
			Supply Min Flow	400	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	172	9:00 AM	384	5:00 PM	400
2:00 AM	172	10:00 AM	384	6:00 PM	320
3:00 AM	168	11:00 AM	384	7:00 PM	184
4:00 AM	168	Noon	304	8:00 PM	184
5:00 AM	168	1:00 PM	388	9:00 PM	184
6:00 AM	164	2:00 PM	392	10:00 PM	180
7:00 AM	300	3:00 PM	396	11:00 PM	176
8:00 AM	384	4:00 PM	396	Midnight	176

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 19

Room Name 102  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Negative	
Calc Max Cooling Flow?	No	
Max Cooling Flow	450	CFM
Room Area	275.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	3,026	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	2	
Occupied ACH Flow	90	CFM
Unoccupied ACH	2	
Unoccupied ACH Flow	90	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	0	CFM
Fixed Offset Flow	0	CFM

Hood Count	0	
Hood Max Flow	0	CFM
Hood Min Flow	0	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	450	CFM
GEX Min Flow	90	CFM
Other Exhaust Max Flow	0	CFM
Other Exhaust Min Flow	0	CFM
Total Exhaust Max Flow	450	CFM
Total Exhaust Min Flow	90	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	450	CFM
Supply Min Flow	90	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	194	9:00 AM	432	5:00 PM	450
2:00 AM	194	10:00 AM	432	6:00 PM	360
3:00 AM	189	11:00 AM	432	7:00 PM	207
4:00 AM	189	Noon	342	8:00 PM	207
5:00 AM	189	1:00 PM	437	9:00 PM	207
6:00 AM	185	2:00 PM	441	10:00 PM	203
7:00 AM	338	3:00 PM	446	11:00 PM	198
8:00 AM	432	4:00 PM	446	Midnight	198

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 20

Room Name 103  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Negative	
Calc Max Cooling Flow?	No	
Max Cooling Flow	240	CFM
Room Area	170.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	1,870	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	1	
Occupied ACH Flow	35	CFM
Unoccupied ACH	1	
Unoccupied ACH Flow	35	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	0	CFM
Fixed Offset Flow	0	CFM

Hood Count	0	
Hood Max Flow	0	CFM
Hood Min Flow	0	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	240	CFM
GEX Min Flow	35	CFM
Other Exhaust Max Flow	0	CFM
Other Exhaust Min Flow	0	CFM
Total Exhaust Max Flow	240	CFM
Total Exhaust Min Flow	35	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	240	CFM
Supply Min Flow	35	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	103	9:00 AM	230	5:00 PM	240
2:00 AM	103	10:00 AM	230	6:00 PM	192
3:00 AM	101	11:00 AM	230	7:00 PM	110
4:00 AM	101	Noon	182	8:00 PM	110
5:00 AM	101	1:00 PM	233	9:00 PM	110
6:00 AM	98	2:00 PM	235	10:00 PM	108
7:00 AM	180	3:00 PM	238	11:00 PM	106
8:00 AM	230	4:00 PM	238	Midnight	106

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 21

Room Name 103A  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Negative	
Calc Max Cooling Flow?	No	
Max Cooling Flow	280	CFM
Room Area	232.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	2,552	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	1	
Occupied ACH Flow	35	CFM
Unoccupied ACH	1	
Unoccupied ACH Flow	35	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	0	CFM
Fixed Offset Flow	0	CFM

Hood Count	0	
Hood Max Flow	0	CFM
Hood Min Flow	0	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	280	CFM
GEX Min Flow	35	CFM
Other Exhaust Max Flow	0	CFM
Other Exhaust Min Flow	0	CFM
Total Exhaust Max Flow	280	CFM
Total Exhaust Min Flow	35	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	280	CFM
Supply Min Flow	35	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	120	9:00 AM	269	5:00 PM	280
2:00 AM	120	10:00 AM	269	6:00 PM	224
3:00 AM	118	11:00 AM	269	7:00 PM	129
4:00 AM	118	Noon	213	8:00 PM	129
5:00 AM	118	1:00 PM	272	9:00 PM	129
6:00 AM	115	2:00 PM	274	10:00 PM	126
7:00 AM	210	3:00 PM	277	11:00 PM	123
8:00 AM	269	4:00 PM	277	Midnight	123

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 22

Room Name 104  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Negative	
Calc Max Cooling Flow?	No	
Max Cooling Flow	0	CFM
Room Area	300.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	3,300	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	2	
Occupied ACH Flow	125	CFM
Unoccupied ACH	2	
Unoccupied ACH Flow	125	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	125	CFM
Fixed Offset Flow	125	CFM

Hood Count	0	
Hood Max Flow	0	CFM
Hood Min Flow	0	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	125	CFM
GEX Min Flow	125	CFM
Other Exhaust Max Flow	0	CFM
Other Exhaust Min Flow	0	CFM
Total Exhaust Max Flow	125	CFM
Total Exhaust Min Flow	125	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	0	CFM
Supply Min Flow	0	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	0	9:00 AM	0	5:00 PM	0
2:00 AM	0	10:00 AM	0	6:00 PM	0
3:00 AM	0	11:00 AM	0	7:00 PM	0
4:00 AM	0	Noon	0	8:00 PM	0
5:00 AM	0	1:00 PM	0	9:00 PM	0
6:00 AM	0	2:00 PM	0	10:00 PM	0
7:00 AM	0	3:00 PM	0	11:00 PM	0
8:00 AM	0	4:00 PM	0	Midnight	0

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 23

Room Name	105
Room Description	Office
Corridor	Basement
Supply AHU	AHU 1
Exhaust Fan	Efan 1
Central Plant	CP 1

Pressure State	Negative	
Calc Max Cooling Flow?	No	
Max Cooling Flow	140	CFM
Room Area	150.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	1,650	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	3	
Occupied ACH Flow	75	CFM
Unoccupied ACH	3	
Unoccupied ACH Flow	75	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	0	CFM
Fixed Offset Flow	0	CFM

Hood Count	0	
Hood Max Flow	0	CFM
Hood Min Flow	0	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	140	CFM
GEX Min Flow	75	CFM
Other Exhaust Max Flow	0	CFM
Other Exhaust Min Flow	0	CFM
Total Exhaust Max Flow	140	CFM
Total Exhaust Min Flow	75	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	140	CFM
Supply Min Flow	75	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	60	9:00 AM	134	5:00 PM	140
2:00 AM	60	10:00 AM	134	6:00 PM	112
3:00 AM	59	11:00 AM	134	7:00 PM	64
4:00 AM	59	Noon	106	8:00 PM	64
5:00 AM	59	1:00 PM	136	9:00 PM	64
6:00 AM	57	2:00 PM	137	10:00 PM	63
7:00 AM	105	3:00 PM	139	11:00 PM	62
8:00 AM	134	4:00 PM	139	Midnight	62

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 24

Room Name 106  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Positive		Hood Count	0	
Calc Max Cooling Flow?	No		Hood Max Flow	0	CFM
Max Cooling Flow	430		Hood Min Flow	0	CFM
		CFM	Office Max Flow	0	CFM
Room Area	456.00	Sq. Ft	Office Min Flow	0	CFM
Ceiling Height	11.00	Ft	GEX Type	VAV	
Room Volume	5,016	Cubic Feet	GEX Valve Quantity	1	
Room Temp Set Point	74	Deg F	GEX Max Flow	430	CFM
Heat Gain	10	Watts/Sq. Ft	GEX Min Flow	75	CFM
Occupied ACH	1		Other Exhaust Max Flow	0	CFM
Occupied ACH Flow	75	CFM	Other Exhaust Min Flow	0	CFM
Unoccupied ACH	1		Total Exhaust Max Flow	430	CFM
Unoccupied ACH Flow	75	CFM	Total Exhaust Min Flow	75	CFM
Offset Option	10% upto fixed offset flow		Supply Type	VAV	
Offset Flow	0	CFM	Supply Valve Quantity	1	
Fixed Offset Flow	0	CFM	Supply Max Flow	430	CFM
			Supply Min Flow	75	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	185	9:00 AM	413	5:00 PM	430
2:00 AM	185	10:00 AM	413	6:00 PM	344
3:00 AM	181	11:00 AM	413	7:00 PM	198
4:00 AM	181	Noon	327	8:00 PM	198
5:00 AM	181	1:00 PM	417	9:00 PM	198
6:00 AM	176	2:00 PM	421	10:00 PM	194
7:00 AM	323	3:00 PM	426	11:00 PM	189
8:00 AM	413	4:00 PM	426	Midnight	189



Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 25

Room Name 107  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Negative	
Calc Max Cooling Flow?	Yes	
Max Cooling Flow	499	CFM
Room Area	300.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	3,300	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	6	
Occupied ACH Flow	330	CFM
Unoccupied ACH	6	
Unoccupied ACH Flow	330	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	250	CFM
Fixed Offset Flow	250	CFM

Hood Count	8	
Hood Max Flow	4,800	CFM
Hood Min Flow	2,600	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	0	CFM
GEX Min Flow	0	CFM
Other Exhaust Max Flow	195	CFM
Other Exhaust Min Flow	195	CFM
Total Exhaust Max Flow	4,995	CFM
Total Exhaust Min Flow	2,795	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	4,745	CFM
Supply Min Flow	2,545	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	215	9:00 AM	479	5:00 PM	499
2:00 AM	215	10:00 AM	479	6:00 PM	399
3:00 AM	210	11:00 AM	479	7:00 PM	230
4:00 AM	210	Noon	379	8:00 PM	230
5:00 AM	210	1:00 PM	484	9:00 PM	230
6:00 AM	205	2:00 PM	489	10:00 PM	225
7:00 AM	374	3:00 PM	494	11:00 PM	220
8:00 AM	479	4:00 PM	494	Midnight	220

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 26

Room Name 108  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Negative	
Calc Max Cooling Flow?	No	
Max Cooling Flow	1,100	CFM
Room Area	504.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	5,544	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	8	
Occupied ACH Flow	781	CFM
Unoccupied ACH	8	
Unoccupied ACH Flow	781	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	75	CFM
Fixed Offset Flow	75	CFM

Hood Count	0	
Hood Max Flow	0	CFM
Hood Min Flow	0	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	1,175	CFM
GEX Min Flow	781	CFM
Other Exhaust Max Flow	0	CFM
Other Exhaust Min Flow	0	CFM
Total Exhaust Max Flow	1,175	CFM
Total Exhaust Min Flow	781	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	1,100	CFM
Supply Min Flow	706	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	473	9:00 AM	1,056	5:00 PM	1,100
2:00 AM	473	10:00 AM	1,056	6:00 PM	880
3:00 AM	462	11:00 AM	1,056	7:00 PM	506
4:00 AM	462	Noon	836	8:00 PM	506
5:00 AM	462	1:00 PM	1,067	9:00 PM	506
6:00 AM	451	2:00 PM	1,078	10:00 PM	495
7:00 AM	825	3:00 PM	1,089	11:00 PM	484
8:00 AM	1,056	4:00 PM	1,089	Midnight	484

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 27

Room Name 109  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Negative	
Calc Max Cooling Flow?	No	
Max Cooling Flow	2,340	CFM
Room Area	1,296.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	14,256	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	6	
Occupied ACH Flow	1,426	CFM
Unoccupied ACH	6	
Unoccupied ACH Flow	1,426	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	250	CFM
Fixed Offset Flow	250	CFM

Hood Count	9	
Hood Max Flow	5,625	CFM
Hood Min Flow	2,925	CFM
Office Max Flow	1,080	CFM
Office Min Flow	555	CFM
GEX Type	VAV	
GEX Valve Quantity	5	
GEX Max Flow	670	CFM
GEX Min Flow	175	CFM
Other Exhaust Max Flow	75	CFM
Other Exhaust Min Flow	75	CFM
Total Exhaust Max Flow	5,875	CFM
Total Exhaust Min Flow	3,175	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	5,070	CFM
Supply Min Flow	1,845	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	1,006	9:00 AM	2,246	5:00 PM	2,340
2:00 AM	1,006	10:00 AM	2,246	6:00 PM	1,872
3:00 AM	983	11:00 AM	2,246	7:00 PM	1,076
4:00 AM	983	Noon	1,778	8:00 PM	1,076
5:00 AM	983	1:00 PM	2,270	9:00 PM	1,076
6:00 AM	959	2:00 PM	2,293	10:00 PM	1,053
7:00 AM	1,755	3:00 PM	2,317	11:00 PM	1,030
8:00 AM	2,246	4:00 PM	2,317	Midnight	1,030

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 28

Room Name 120  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Positive		Hood Count	0	
Calc Max Cooling Flow?	No		Hood Max Flow	0	CFM
Max Cooling Flow	385		Hood Min Flow	0	CFM
		CFM	Office Max Flow	0	CFM
Room Area	300.00	Sq. Ft	Office Min Flow	0	CFM
Ceiling Height	11.00	Ft	GEX Type	VAV	
Room Volume	3,300	Cubic Feet	GEX Valve Quantity	1	
Room Temp Set Point	74	Deg F	GEX Max Flow	0	CFM
Heat Gain	10	Watts/Sq. Ft	GEX Min Flow	0	CFM
Occupied ACH	7		Other Exhaust Max Flow	0	CFM
Occupied ACH Flow	385	CFM	Other Exhaust Min Flow	0	CFM
Unoccupied ACH	7		Total Exhaust Max Flow	0	CFM
Unoccupied ACH Flow	385	CFM	Total Exhaust Min Flow	0	CFM
Offset Option	10% upto fixed offset flow		Supply Type	VAV	
Offset Flow	-385	CFM	Supply Valve Quantity	1	
Fixed Offset Flow	385	CFM	Supply Max Flow	385	CFM
			Supply Min Flow	385	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	166	9:00 AM	370	5:00 PM	385
2:00 AM	166	10:00 AM	370	6:00 PM	308
3:00 AM	162	11:00 AM	370	7:00 PM	177
4:00 AM	162	Noon	293	8:00 PM	177
5:00 AM	162	1:00 PM	373	9:00 PM	177
6:00 AM	158	2:00 PM	377	10:00 PM	173
7:00 AM	289	3:00 PM	381	11:00 PM	169
8:00 AM	370	4:00 PM	381	Midnight	169

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 29

Room Name 201  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Positive		Hood Count	0	
Calc Max Cooling Flow?	No		Hood Max Flow	0	CFM
Max Cooling Flow	360	CFM	Hood Min Flow	0	CFM
Room Area	232.00	Sq. Ft	Office Max Flow	0	CFM
Ceiling Height	11.00	Ft	Office Min Flow	0	CFM
Room Volume	2,552	Cubic Feet	GEX Type	VAV	
Room Temp Set Point	74	Deg F	GEX Valve Quantity	1	
Heat Gain	10	Watts/Sq. Ft	GEX Max Flow	360	CFM
Occupied ACH	1		GEX Min Flow	35	CFM
Occupied ACH Flow	35	CFM	Other Exhaust Max Flow	0	CFM
Unoccupied ACH	1		Other Exhaust Min Flow	0	CFM
Unoccupied ACH Flow	35	CFM	Total Exhaust Max Flow	360	CFM
Offset Option	10% upto fixed offset flow		Total Exhaust Min Flow	35	CFM
Offset Flow	0	CFM	Supply Type	VAV	
Fixed Offset Flow	0	CFM	Supply Valve Quantity	1	
			Supply Max Flow	360	CFM
			Supply Min Flow	35	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	155	9:00 AM	346	5:00 PM	360
2:00 AM	155	10:00 AM	346	6:00 PM	288
3:00 AM	151	11:00 AM	346	7:00 PM	166
4:00 AM	151	Noon	274	8:00 PM	166
5:00 AM	151	1:00 PM	349	9:00 PM	166
6:00 AM	148	2:00 PM	353	10:00 PM	162
7:00 AM	270	3:00 PM	356	11:00 PM	158
8:00 AM	346	4:00 PM	356	Midnight	158

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 30

Room Name 202  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Negative	
Calc Max Cooling Flow?	No	
Max Cooling Flow	1,175	CFM
Room Area	324.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	3,564	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	9	
Occupied ACH Flow	525	CFM
Unoccupied ACH	4	
Unoccupied ACH Flow	525	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	125	CFM
Fixed Offset Flow	125	CFM

Hood Count	1	
Hood Max Flow	750	CFM
Hood Min Flow	150	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	925	CFM
GEX Min Flow	50	CFM
Other Exhaust Max Flow	225	CFM
Other Exhaust Min Flow	225	CFM
Total Exhaust Max Flow	1,300	CFM
Total Exhaust Min Flow	525	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	1,175	CFM
Supply Min Flow	400	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	505	9:00 AM	1,128	5:00 PM	1,175
2:00 AM	505	10:00 AM	1,128	6:00 PM	940
3:00 AM	494	11:00 AM	1,128	7:00 PM	541
4:00 AM	494	Noon	893	8:00 PM	541
5:00 AM	494	1:00 PM	1,140	9:00 PM	541
6:00 AM	482	2:00 PM	1,152	10:00 PM	529
7:00 AM	881	3:00 PM	1,163	11:00 PM	517
8:00 AM	1,128	4:00 PM	1,163	Midnight	517

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 31

Room Name 203  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Negative	
Calc Max Cooling Flow?	No	
Max Cooling Flow	615	CFM
Room Area	390.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	4,290	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	27	
Occupied ACH Flow	1,925	CFM
Unoccupied ACH	27	
Unoccupied ACH Flow	1,925	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	115	CFM
Fixed Offset Flow	115	CFM

Hood Count	1	
Hood Max Flow	1,500	CFM
Hood Min Flow	1,500	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	0	CFM
GEX Min Flow	0	CFM
Other Exhaust Max Flow	425	CFM
Other Exhaust Min Flow	425	CFM
Total Exhaust Max Flow	1,925	CFM
Total Exhaust Min Flow	1,925	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	1,810	CFM
Supply Min Flow	1,810	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	264	9:00 AM	590	5:00 PM	615
2:00 AM	264	10:00 AM	590	6:00 PM	492
3:00 AM	258	11:00 AM	590	7:00 PM	283
4:00 AM	258	Noon	467	8:00 PM	283
5:00 AM	258	1:00 PM	597	9:00 PM	283
6:00 AM	252	2:00 PM	603	10:00 PM	277
7:00 AM	461	3:00 PM	609	11:00 PM	271
8:00 AM	590	4:00 PM	609	Midnight	271

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 32

Room Name 204  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Positive	
Calc Max Cooling Flow?	No	
Max Cooling Flow	450	CFM
Room Area	285.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	3,136	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	1	
Occupied ACH Flow	50	CFM
Unoccupied ACH	1	
Unoccupied ACH Flow	50	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	0	CFM
Fixed Offset Flow	0	CFM

Hood Count	0	
Hood Max Flow	0	CFM
Hood Min Flow	0	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	450	CFM
GEX Min Flow	50	CFM
Other Exhaust Max Flow	0	CFM
Other Exhaust Min Flow	0	CFM
Total Exhaust Max Flow	450	CFM
Total Exhaust Min Flow	50	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	450	CFM
Supply Min Flow	50	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	194	9:00 AM	432	5:00 PM	450
2:00 AM	194	10:00 AM	432	6:00 PM	360
3:00 AM	189	11:00 AM	432	7:00 PM	207
4:00 AM	189	Noon	342	8:00 PM	207
5:00 AM	189	1:00 PM	437	9:00 PM	207
6:00 AM	185	2:00 PM	441	10:00 PM	203
7:00 AM	338	3:00 PM	446	11:00 PM	198
8:00 AM	432	4:00 PM	446	Midnight	198



Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 33

Room Name 205  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Negative	
Calc Max Cooling Flow?	No	
Max Cooling Flow	450	CFM
Room Area	287.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	3,158	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	9	
Occupied ACH Flow	450	CFM
Unoccupied ACH	9	
Unoccupied ACH Flow	450	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	0	CFM
Fixed Offset Flow	0	CFM

Hood Count	0	
Hood Max Flow	0	CFM
Hood Min Flow	0	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	450	CFM
GEX Min Flow	450	CFM
Other Exhaust Max Flow	0	CFM
Other Exhaust Min Flow	0	CFM
Total Exhaust Max Flow	450	CFM
Total Exhaust Min Flow	450	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	450	CFM
Supply Min Flow	450	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	194	9:00 AM	432	5:00 PM	450
2:00 AM	194	10:00 AM	432	6:00 PM	360
3:00 AM	189	11:00 AM	432	7:00 PM	207
4:00 AM	189	Noon	342	8:00 PM	207
5:00 AM	189	1:00 PM	437	9:00 PM	207
6:00 AM	185	2:00 PM	441	10:00 PM	203
7:00 AM	338	3:00 PM	446	11:00 PM	198
8:00 AM	432	4:00 PM	446	Midnight	198

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 34

Room Name 206  
 Room Description 5 hoods  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Negative	
Calc Max Cooling Flow?	No	
Max Cooling Flow	2,875	CFM
Room Area	798.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	8,778	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	6	
Occupied ACH Flow	879	CFM
Unoccupied ACH	6	
Unoccupied ACH Flow	878	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	125	CFM
Fixed Offset Flow	125	CFM

Hood Count	5	
Hood Max Flow	2,915	CFM
Hood Min Flow	1,935	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	615	CFM
GEX Min Flow	35	CFM
Other Exhaust Max Flow	450	CFM
Other Exhaust Min Flow	450	CFM
Total Exhaust Max Flow	3,400	CFM
Total Exhaust Min Flow	2,420	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	3,275	CFM
Supply Min Flow	2,295	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	1,236	9:00 AM	2,760	5:00 PM	2,875
2:00 AM	1,236	10:00 AM	2,760	6:00 PM	2,300
3:00 AM	1,208	11:00 AM	2,760	7:00 PM	1,323
4:00 AM	1,208	Noon	2,185	8:00 PM	1,323
5:00 AM	1,208	1:00 PM	2,789	9:00 PM	1,323
6:00 AM	1,179	2:00 PM	2,818	10:00 PM	1,294
7:00 AM	2,156	3:00 PM	2,846	11:00 PM	1,265
8:00 AM	2,760	4:00 PM	2,846	Midnight	1,265

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 35

Room Name 207  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Negative	
Calc Max Cooling Flow?	No	
Max Cooling Flow	2,445	CFM
Room Area	1,012.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	11,132	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	6	
Occupied ACH Flow	1,114	CFM
Unoccupied ACH	6	
Unoccupied ACH Flow	1,114	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	125	CFM
Fixed Offset Flow	125	CFM

Hood Count	5	
Hood Max Flow	3,160	CFM
Hood Min Flow	1,935	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	635	CFM
GEX Min Flow	35	CFM
Other Exhaust Max Flow	0	CFM
Other Exhaust Min Flow	0	CFM
Total Exhaust Max Flow	3,195	CFM
Total Exhaust Min Flow	1,970	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	3,070	CFM
Supply Min Flow	1,845	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	1,051	9:00 AM	2,347	5:00 PM	2,445
2:00 AM	1,051	10:00 AM	2,347	6:00 PM	1,956
3:00 AM	1,027	11:00 AM	2,347	7:00 PM	1,125
4:00 AM	1,027	Noon	1,858	8:00 PM	1,125
5:00 AM	1,027	1:00 PM	2,372	9:00 PM	1,125
6:00 AM	1,002	2:00 PM	2,396	10:00 PM	1,100
7:00 AM	1,834	3:00 PM	2,421	11:00 PM	1,076
8:00 AM	2,347	4:00 PM	2,421	Midnight	1,076

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 36

Room Name	208
Room Description	
Corridor	Basement
Supply AHU	AHU 1
Exhaust Fan	Efan 1
Central Plant	CP 1

Pressure State	Negative	
Calc Max Cooling Flow?	No	
Max Cooling Flow	2,470	CFM
Room Area	506.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	5,566	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	6	
Occupied ACH Flow	557	CFM
Unoccupied ACH	6	
Unoccupied ACH Flow	557	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	125	CFM
Fixed Offset Flow	125	CFM

Hood Count	5	
Hood Max Flow	3,140	CFM
Hood Min Flow	1,935	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	585	CFM
GEX Min Flow	35	CFM
Other Exhaust Max Flow	75	CFM
Other Exhaust Min Flow	75	CFM
Total Exhaust Max Flow	3,250	CFM
Total Exhaust Min Flow	2,045	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	3,125	CFM
Supply Min Flow	1,920	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	1,062	9:00 AM	2,371	5:00 PM	2,470
2:00 AM	1,062	10:00 AM	2,371	6:00 PM	1,976
3:00 AM	1,037	11:00 AM	2,371	7:00 PM	1,136
4:00 AM	1,037	Noon	1,877	8:00 PM	1,136
5:00 AM	1,037	1:00 PM	2,396	9:00 PM	1,136
6:00 AM	1,013	2:00 PM	2,421	10:00 PM	1,112
7:00 AM	1,853	3:00 PM	2,445	11:00 PM	1,087
8:00 AM	2,371	4:00 PM	2,445	Midnight	1,087

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 37

Room Name 209  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Negative	
Calc Max Cooling Flow?	No	
Max Cooling Flow	1,855	CFM
Room Area	798.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	8,778	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	6	
Occupied ACH Flow	878	CFM
Unoccupied ACH	6	
Unoccupied ACH Flow	878	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	125	CFM
Fixed Offset Flow	125	CFM

Hood Count	6	
Hood Max Flow	4,325	CFM
Hood Min Flow	3,125	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	0	CFM
GEX Min Flow	0	CFM
Other Exhaust Max Flow	0	CFM
Other Exhaust Min Flow	0	CFM
Total Exhaust Max Flow	4,325	CFM
Total Exhaust Min Flow	3,125	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	4,200	CFM
Supply Min Flow	3,000	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	798	9:00 AM	1,781	5:00 PM	1,855
2:00 AM	798	10:00 AM	1,781	6:00 PM	1,484
3:00 AM	779	11:00 AM	1,781	7:00 PM	853
4:00 AM	779	Noon	1,410	8:00 PM	853
5:00 AM	779	1:00 PM	1,799	9:00 PM	853
6:00 AM	761	2:00 PM	1,818	10:00 PM	835
7:00 AM	1,391	3:00 PM	1,836	11:00 PM	816
8:00 AM	1,781	4:00 PM	1,836	Midnight	816

Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 38

Room Name 220  
 Room Description  
 Corridor Basement  
 Supply AHU AHU 1  
 Exhaust Fan Efan 1  
 Central Plant CP 1

Pressure State	Positive	
Calc Max Cooling Flow?	No	
Max Cooling Flow	375	CFM
Room Area	300.00	Sq. Ft
Ceiling Height	11.00	Ft
Room Volume	3,300	Cubic Feet
Room Temp Set Point	74	Deg F
Heat Gain	10	Watts/Sq. Ft
Occupied ACH	7	
Occupied ACH Flow	375	CFM
Unoccupied ACH	7	
Unoccupied ACH Flow	375	CFM
Offset Option	10% upto fixed offset flow	
Offset Flow	-375	CFM
Fixed Offset Flow	375	CFM

Hood Count	0	
Hood Max Flow	0	CFM
Hood Min Flow	0	CFM
Office Max Flow	0	CFM
Office Min Flow	0	CFM
GEX Type	VAV	
GEX Valve Quantity	1	
GEX Max Flow	0	CFM
GEX Min Flow	0	CFM
Other Exhaust Max Flow	0	CFM
Other Exhaust Min Flow	0	CFM
Total Exhaust Max Flow	0	CFM
Total Exhaust Min Flow	0	CFM
Supply Type	VAV	
Supply Valve Quantity	1	
Supply Max Flow	375	CFM
Supply Min Flow	375	CFM

Room Maximum Cooling Flow Profile

Flow Unit: CFM

1:00 AM	161	9:00 AM	360	5:00 PM	375
2:00 AM	161	10:00 AM	360	6:00 PM	300
3:00 AM	158	11:00 AM	360	7:00 PM	173
4:00 AM	158	Noon	285	8:00 PM	173
5:00 AM	158	1:00 PM	364	9:00 PM	173
6:00 AM	154	2:00 PM	368	10:00 PM	169
7:00 AM	281	3:00 PM	371	11:00 PM	165
8:00 AM	360	4:00 PM	371	Midnight	165

Exhaust Fan System							
Name	Area Served	Control Type	Design Flow	Design Power	Static Pressure	Fan Efficiency	Speed Control
Efan 1	Main Exhaust	CV	42,435 CFM	41.8 Hp	5.00 "w.c.	80 %	Constant Air Volume
		VAV	40,200 CFM	39.6 Hp			
		CV-UBC	36,010 CFM	35.5 Hp			
		VAV-UBC	35,323 CFM	34.8 Hp			
Total		CV	42,435 CFM	41.8 Hp			
		VAV	40,200 CFM	39.6 Hp			
		CV-UBC	36,010 CFM	35.5 Hp			
		VAV-UBC	35,323 CFM	34.8 Hp			

Supply AHU System							
Name	Area Served	Control Type	Design Flow	Design Power	Static Pressure	Fan Efficiency	Speed Control
AHU 1	Main Supply	CV	41,345 CFM	40.7 Hp	5.00 "w.c.	80 %	Variable Frequency Drive
		VAV	39,110 CFM	38.5 Hp			
		CV-UBC	34,920 CFM	34.4 Hp			
		VAV-UBC	34,233 CFM	33.7 Hp			
Total		CV	41,345 CFM	40.7 Hp			
		VAV	39,110 CFM	38.5 Hp			
		CV-UBC	34,920 CFM	34.4 Hp			
		VAV-UBC	34,233 CFM	33.7 Hp			

Central Plant System					
Name	Area Served	SAT Cooling Temp	SAT Heating Temp	Cooling Efficiency	Heating Efficiency
CP 1	Main	55 Deg F	55 Deg F	1.10 kW/Ton	80 %

# System Diversity Comparison

## Stanford Stauffer Hall - Retrofit

October 23, 2010

<b>System Diversity Comparison</b>
------------------------------------

*Flow Unit: CFM*

	Exhaust System <i>99.00% Design</i>			Supply System <i>99.00% Design</i>			Central Plant <i>99.00% Design</i>		
	Diversity	Design Flow	Average Flow	Diversity	Design Flow	Average Flow	Diversity	Design Flow	Average Flow
<b>CV</b>	100 %	42,435	42,435	100 %	41,345	41,345	100 %	41,345	41,345
<b>CV-UBC</b>	85 %	36,010	32,028	84 %	34,920	30,938	84 %	34,920	30,938
<b>VAV</b>	95 %	40,200	37,286	95 %	39,110	36,196	95 %	39,110	36,196
<b>VAV-UBC</b>	83 %	35,323	30,994	83 %	34,233	29,904	83 %	34,233	29,904

Diversity Calculation: Control Type Design Flow / Constant Volume Design Flow

<b>Exhaust Fan System Flow Diversity</b>				
Efan 1				
	<b>CV</b>	<b>CV-UBC</b>	<b>VAV</b>	<b>VAV-UBC</b>
<b>Average Flow</b>	42,435 <i>CFM</i>	32,028 <i>CFM</i>	37,286 <i>CFM</i>	30,994 <i>CFM</i>
<b>Design Flow</b>	42,435 <i>CFM</i>	36,010 <i>CFM</i>	40,200 <i>CFM</i>	35,323 <i>CFM</i>
<b>Diversity</b>	100 %	85 %	95 %	83 %
<b>Total Average Flow</b>	<b>42,435</b> <i>CFM</i>	<b>32,028</b> <i>CFM</i>	<b>37,286</b> <i>CFM</i>	<b>30,994</b> <i>CFM</i>
<b>Total Design Flow</b>	<b>42,435</b> <i>CFM</i>	<b>36,010</b> <i>CFM</i>	<b>40,200</b> <i>CFM</i>	<b>35,323</b> <i>CFM</i>

<b>Supply System Flow Diversity</b>				
AHU 1				
	<b>CV</b>	<b>CV-UBC</b>	<b>VAV</b>	<b>VAV-UBC</b>
<b>Average Flow</b>	41,345 <i>CFM</i>	30,938 <i>CFM</i>	36,196 <i>CFM</i>	29,904 <i>CFM</i>
<b>Design Flow</b>	41,345 <i>CFM</i>	34,920 <i>CFM</i>	39,110 <i>CFM</i>	34,233 <i>CFM</i>
<b>Diversity</b>	100 %	84 %	95 %	83 %
<b>Total Average Flow</b>	<b>41,345</b> <i>CFM</i>	<b>30,938</b> <i>CFM</i>	<b>36,196</b> <i>CFM</i>	<b>29,904</b> <i>CFM</i>
<b>Total Design Flow</b>	<b>41,345</b> <i>CFM</i>	<b>34,920</b> <i>CFM</i>	<b>39,110</b> <i>CFM</i>	<b>34,233</b> <i>CFM</i>

<b>Central Plant System Flow Diversity</b>				
CP 1				
	<b>CV</b>	<b>CV-UBC</b>	<b>VAV</b>	<b>VAV-UBC</b>
<b>Average Flow</b>	41,345 <i>CFM</i>	30,938 <i>CFM</i>	36,196 <i>CFM</i>	29,904 <i>CFM</i>
<b>Design Flow</b>	41,345 <i>CFM</i>	34,920 <i>CFM</i>	39,110 <i>CFM</i>	34,233 <i>CFM</i>
<b>Diversity</b>	100 %	84 %	95 %	83 %
<b>Total Average Flow</b>	<b>41,345</b> <i>CFM</i>	<b>30,938</b> <i>CFM</i>	<b>36,196</b> <i>CFM</i>	<b>29,904</b> <i>CFM</i>
<b>Total Design Flow</b>	<b>41,345</b> <i>CFM</i>	<b>34,920</b> <i>CFM</i>	<b>39,110</b> <i>CFM</i>	<b>34,233</b> <i>CFM</i>



## Fume Hood Summary

### Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 1

Room Name	Hood Name	Hood Type	Daily User Presence Hours	Sash Width	Sash Height	Maximum Flow	Minimum Flow
008	Hood 37	5' VAV	1.00	52 inches	28 inches	1,000 CFM	325 CFM
008	Hood 38	5' VAV	1.00	52 inches	28 inches	1,000 CFM	325 CFM
107	Hood 43	5' VAV	1.00	52 inches	28 inches	600 CFM	325 CFM
107	Hood 44	5' VAV	1.00	52 inches	28 inches	600 CFM	325 CFM
107	Hood 45	5' VAV	1.00	52 inches	28 inches	600 CFM	325 CFM
107	Hood 46	5' VAV	1.00	52 inches	28 inches	600 CFM	325 CFM
107	Hood 47	5' VAV	1.00	52 inches	28 inches	600 CFM	325 CFM
107	Hood 48	5' VAV	1.00	52 inches	28 inches	600 CFM	325 CFM
107	Hood 49	5' VAV	1.00	52 inches	28 inches	600 CFM	325 CFM
107	Hood 50	5' VAV	1.00	52 inches	28 inches	600 CFM	325 CFM
109	Hood 31	5' VAV	1.00	52 inches	28 inches	625 CFM	325 CFM
109	Hood 32	5' VAV	1.00	52 inches	28 inches	625 CFM	325 CFM
109	Hood 33	5' VAV	1.00	52 inches	28 inches	625 CFM	325 CFM
109	Hood 34	5' VAV	1.00	52 inches	28 inches	625 CFM	325 CFM
109	Hood 35	5' VAV	1.00	52 inches	28 inches	625 CFM	325 CFM
109	Hood 36	5' VAV	1.00	52 inches	28 inches	625 CFM	325 CFM
109	Hood 40	5' VAV	1.00	52 inches	28 inches	625 CFM	325 CFM
109	Hood 41	5' VAV	1.00	52 inches	28 inches	625 CFM	325 CFM
109	Hood 42	5' VAV	1.00	52 inches	28 inches	625 CFM	325 CFM
202	Hood 22	4' VAV	1.00	41 inches	28 inches	750 CFM	150 CFM
203	Hood 21	8' Walk-in	1.00	88 inches	56 inches	1,500 CFM	1,500 CFM
206	Hood 1	5' VAV	1.00	52 inches	28 inches	550 CFM	325 CFM
206	Hood 2	5' VAV	1.00	52 inches	28 inches	550 CFM	325 CFM
206	Hood 3	5' VAV	1.00	52 inches	28 inches	550 CFM	325 CFM
206	Hood 4	5' VAV	1.00	52 inches	28 inches	550 CFM	325 CFM
206	Hood 5	6' VAV	1.00	64 inches	28 inches	715 CFM	635 CFM
207	Hood 06	5' VAV	1.00	52 inches	28 inches	580 CFM	325 CFM
207	Hood 07	5' VAV	1.00	52 inches	28 inches	580 CFM	325 CFM
207	Hood 08	5' VAV	1.00	52 inches	28 inches	580 CFM	325 CFM
207	Hood 09	5' VAV	1.00	52 inches	28 inches	580 CFM	325 CFM

## Fume Hood Summary

### Stanford Stauffer Hall - Retrofit

October 23, 2010

Page 2

Room Name	Hood Name	Hood Type	Daily User Presence Hours	Sash Width	Sash Height	Maximum Flow	Minimum Flow
207	Hood 10	6' VAV	1.00	64 inches	28 inches	840 CFM	635 CFM
208	Hood 11	5' VAV	1.00	52 inches	28 inches	580 CFM	325 CFM
208	Hood 12	5' VAV	1.00	52 inches	28 inches	580 CFM	325 CFM
208	Hood 13	5' VAV	1.00	52 inches	28 inches	580 CFM	325 CFM
208	Hood 14	5' VAV	1.00	52 inches	28 inches	580 CFM	325 CFM
208	Hood 15	6' VAV	1.00	64 inches	28 inches	820 CFM	635 CFM
209	Hood 16	5' VAV	1.00	52 inches	28 inches	565 CFM	325 CFM
209	Hood 17	5' VAV	1.00	52 inches	28 inches	565 CFM	325 CFM
209	Hood 18	5' VAV	1.00	52 inches	28 inches	565 CFM	325 CFM
209	Hood 19	5' VAV	1.00	52 inches	28 inches	565 CFM	325 CFM
209	Hood 20	5' VAV	1.00	52 inches	28 inches	565 CFM	325 CFM
209	Hood 39	8' Walk-in	1.00	88 inches	56 inches	1,500 CFM	1,500 CFM

## Project Defaults

<b>Project Name</b>	Stanford Stauffer Hall	October 23, 2010
<b>Project Description</b>	Retrofit	Page 1
<b>Company Name</b>		
<b>Contact</b>		
<b>Address</b>		
<b>Phone</b>		

### General

Occupied Hour	8:00:00 AM
Unoccupied Hour	6:00:00 PM
Exhaust System Design Percentile	99.00 %
Supply System Design Percentile	99.00 %
Central Plant Design Percentile	99.00 %
Weather Station	San Jose

### Room and Corridor

Corridor Floor Area	1,000.00	<i>Sq. Ft</i>
Corridor Heat Gain	2.00	<i>Watts/Sq. Ft</i>
Corridor ACH	4.00	
Room Ceiling Height	11.00	<i>Ft</i>
Room Floor Area	300	<i>Sq. Ft</i>
Room Temperature	74	<i>Deg F</i>
Room Heat Gain	10.00	<i>Watts/Sq. Ft</i>
Room ACH Occupied	6.00	
Room ACH Unoccupied	6.00	
VAV GEX Quantity	1	
VAV Supply Quantity	1	
Offset Percentage	10%	

### Hood Usage

UBC Flow Normal Mode	100 %
UBC Flow Standby Mode	60 %
Sash Position with User Present	100 %
Sash Position with User Absent	50 %

### Fan and Central Plant

Cooling Efficiency	1.10	<i>kW/Ton</i>
Heating Efficiency	80 %	
Supply Air Temperature (Cooling)	55	<i>Deg F</i>
Supply Air Temperature (Heating)	55	<i>Deg F</i>
Supply AHU Static Pressure	5.00	<i>"w.c.</i>
Supply AHU Efficiency	65 %	
Supply AHU Control Type	Variable Frequency Drive	
Exhaust Fan Static Pressure	5.00	<i>"w.c.</i>
Exhaust Fan Efficiency	65 %	
Exhaust Fan Control Type	Variable Frequency Drive	

### HVAC Initial Costs

Cooling System Cost	0.00	<i>USD</i>
Heating System Cost	0.00	<i>USD</i>
Reheat System Cost	0.00	<i>USD</i>
Duct Cost	0.00	<i>USD</i>
Supply AHU Cost	0.00	<i>USD</i>
Exhaust Fan Cost	0.00	<i>USD</i>
VFD Cost	0.00	<i>USD</i>
Filter Cost	0.00	<i>USD</i>
ATC Cost	0.00	<i>USD</i>
ATC Interface Cost	0.00	<i>USD</i>
VAV-UBC Controls Cost	1,100,000.00	<i>USD</i>
VAV-Phoenix Controls Cost	1,050,000.00	<i>USD</i>
VAV-Other Controls Cost	1,050,000.00	<i>USD</i>
CV-UBC Controls Cost	900,000.00	<i>USD</i>
CV-Phoenix Controls Cost	0.00	<i>USD</i>
CV-Other Controls Cost	0.00	<i>USD</i>

### Operating Costs

Interest Rate	5 %	
Hurdle Rate	3 %	
Analysis Period	15 <i>Years</i>	
Balancing Cost-Phoenix	100.00	<i>USD</i>
Balancing Cost-Other	250.00	<i>USD</i>
Certification Cost-Phoenix	25.00	<i>USD</i>
Certification Cost-Other	50.00	<i>USD</i>
Lab Downtime Cost	20.00	<i>USD</i>
CV Maint. Cost-Other	300.00	<i>USD</i>
VAV Maint. Cost-Other	750.00	<i>USD</i>
CV, CV-UBC Maint. Cost-Phoenix	0.00	<i>USD</i>
VAV, VAV-UBC Maint. Cost-Phoenix	0.00	<i>USD</i>
ATC Maintenance Cost per Room	500.00	<i>USD</i>

### Energy Costs

Cooling Fuel Type	Electricity (kWh)	
Cooling Fuel Cost	0.100	<i>USD</i>
Cooling Fuel BTU's	3,413	
Heating Fuel Type	Natural Gas (therm)	
Heating Fuel Cost	0.800	<i>USD</i>
Heating Fuel BTU's	100,000	
Reheat Fuel Type	Natural Gas (therm)	
Reheat Fuel Cost	0.800	<i>USD</i>
Reheat Fuel BTU's	100,000	
Electricity Cost per kWh	0.100	<i>USD</i>

Stanford Stauffer Hall - Retrofit

October 23, 2010  
Page 1

City San Jose  
 State CA  
 Latitude 37 25N  
 Longitude 122 03W  
 Elevation 34  
 Altitude Correction Factor 1.00

Bin Min Temp <i>Deg F</i>	Bin Max Temp <i>Deg F</i>	MCWB <i>Deg F</i>	Midnight to 8 am	8 am to 4 pm	4 pm to Midnight	Total Hours Observed
105.0	109.0	71.0	0	0	0	0
100.0	104.0	70.0	0	0	0	0
95.0	99.0	69.0	0	0	0	0
90.0	94.0	67.0	0	6	0	6
85.0	89.0	66.0	0	21	3	24
80.0	84.0	65.0	0	70	14	84
75.0	79.0	63.0	0	158	49	207
70.0	74.0	62.0	12	370	153	535
65.0	69.0	59.0	76	616	384	1,076
60.0	64.0	56.0	454	624	676	1,754
55.0	59.0	53.0	771	519	685	1,975
50.0	54.0	48.0	668	333	544	1,545
45.0	49.0	44.0	493	144	297	934
40.0	44.0	40.0	310	46	95	451
35.0	39.0	35.0	112	9	17	138
30.0	34.0	31.0	22	1	1	24
25.0	29.0	26.0	1	0	0	1

Total Annual Hours Observed = 8,754

This data was obtained from the U.S. Government National Climactic Center. Differences from 8,760 annual hours are due to rounding.